
**Nelson Mandela Bay Metropolitan Municipality
(Port Elizabeth)**

**City Engineers Department
Building Inspectorate**

Page 1

Building Plan Details

Plan Number:	361982	Area:	64.00m2
Owner Name:	VW SA	Value:	R265,344.00
Applicant Name:	VW SA	Building Type:	AIG
Address:	ALGOA ROAD	Erf Number:	29201
Allotment Area:	UITENHAGE	Units:	
Complex Name:		Bathrooms:	
Description of Work:	PROPOSED ADDITION	Garages:	
Receipt Number:	Y0662	Fee:	R 2388.00
Designer Name:	H GOUWS	SACAP Reg:	PSAT324498
		Age of building:	Unknown

Comments:

SANS	S/T ALL TIMBER USED IN THE ERECTION OF A BUILDING BE TREATED AGAINST TERMITE
SAN2	AND WOOD BORER ATTACK & FUNGAL DECAY IN ACCORDANCE WITH SANS 10005
HMCC	HEALTH TO COMMENT
*POW	POWER OF ATTORNEY (LETTER) REQD.
D03	DRAINAGE PLAN NOT APPROVED
TPMM	TP TO COMMENT

Status:	Not Approved	Plan Status:	None
Application Date:	16-Oct-2024	Date Commenced:	
Date Not Approved/Held:	16-Oct-2024	Date Completed:	
Date Disapproved:		Occupation Certificate Date:	
Date Passed:		Lapsed Date:	
