

ISBN 978-0-626-34193-0

SANS 10400-V:2018

Edition 3.1

SOUTH AFRICAN NATIONAL STANDARD

The application of the National Building Regulations

Part V: Space heating

WARNING

This document references other documents normatively.

Published by the South African Bureau of Standards
1 Dr Lategan Road Groenkloof ☒ Private Bag X191 Pretoria 0001
Tel: +27 12 428 7911 Fax: +27 12 344 1568

www.sabs.co.za

© SABS



This page has been left blank intentionally



COPYRIGHT PROTECTED DOCUMENT

© SABS

In terms of the Standards Act 8 of 2008, the copyright in all South African National Standards or any other publications published by the SABS Standards Division, vests in the SABS. Any use of South African National Standards is limited to use specifically prescribed by the SABS. In the case of a South African National Standard based on an international standard, ownership of the copyright vests in the organization from which the SABS adopted the standard, whether it be under licence or membership agreement. The SABS is obliged to protect such copyright and is authorized to make the relevant international organization aware of any misuse thereof. Unless exemption has been granted, no extract or full text of any South African National Standard may be copied, reproduced, stored in a retrieval system or transmitted in any form or by any means without prior written permission from the SABS Standards Division. This does not preclude the free use, in the course of implementing the standard, of necessary details such as symbols, and size, type or grade designations. If these details are to be used for any purpose other than implementation, prior written permission must be obtained.

Details, advice and limitations of use can be obtained from the Manager: Standards Sales and Information Services. Tel: +27 (0) 12 428 6883 email: sales@sabs.co.za

SABS – Standards Division

The objective of the SABS Standards Division is to develop, promote and maintain South African National Standards. This objective is incorporated in the Standards Act, 2008 (Act No. 8 of 2008).

The SABS continuously strives to improve the quality of its products and services and would therefore be grateful if anyone finding an inaccuracy or ambiguity while using this standard would inform the secretary of the technical committee responsible, the identity of which can be found in the foreword.

Buying Standards

Contact the Sales Office for South African and international standards, which are available in both electronic and hard copy format. Tel: +27 (0) 12 428 6883 email: sales@sabs.co.za

South African National Standards are also available online from the SABS Webstore www.store.sabs.co.za

Information on Standards

SABS Customer Services provide comprehensive standards-related information on national, regional and international standards. Tel: +27 (0) 12 428 7911 / 0861 27 7227 email: info@sabs.co.za

SANS 10400-V:2018

Edition 3.1

Table of changes

Change No.	Date	Scope
Amdt 1	2018	Amended to delete the note to the scope, to update definitions, to update requirements, to update the figure on chimney positions, and to delete the annex on National Building Regulations – Part V: Space heating.

Foreword

This South African standard was prepared by National Committee SABS/TC 060, *Standards which address the National Building Regulations (NBRS)*, in accordance with procedures of the South African Bureau of Standards, in compliance with annex 3 of the WTO/TBT agreement.

This document was approved for publication in April 2018.

This document supersedes SANS 10400-V: 2010 (edition 3).

A vertical line in the margin shows where the text has been technically modified by amendment No. 1.

Compliance with the requirements of this document will be deemed to be compliance with the requirements of part V of the National Building Regulations, issued in terms of the National Building Regulations and Building Standards Act, 1977 (Act No. 103 of 1977).

Compliance with this document cannot confer immunity from legal obligations.

This document should be read in conjunction with SANS 10400-A.

SANS 10400 consists of the following parts, under the general title *The application of the National Building Regulations*:

Part A: General principles and requirements.

Part B: Structural design.

Part C: Dimensions.

Part D: Public safety.

Part F: Site operations.

Part G: Excavations.

Part H: Foundations.

Part J: Floors.

Part K: Walls.

Part L: Roofs.

SANS 10400-V:2018
Edition 3.1

Foreword *(concluded)*

Part M: Stairways.

Part N: Glazing.

Part O: Lighting and ventilation.

Part P: Drainage.

Part Q: Non-water-borne means of sanitary disposal.

Part R: Stormwater disposal.

Part S: Facilities for persons with disabilities.

Part T: Fire protection.

Part V: Space heating.

Part W: Fire installation.

Part X: Environmental sustainability.

Part XA: Energy usage in buildings.

Annex A Deleted by amendment No. 1.

|

SANS 10400-V:2018
Edition 3.1

Contents

	Page
Foreword	
1 Scope	3
2 Normative references	3
3 Definitions	3
4 Requirements	4
4.1 General	4
4.2 Flue pipes	4
4.3 Chimneys	5
4.4 Hearths and fireplaces	5

Annex A Deleted by amendment No. 1.

SANS 10400-V:2018
Edition 3.1

The application of the National Building Regulations

Part V: **Space heating**

1 Scope

This part of SANS 10400 provides deemed-to-satisfy requirements for compliance with part V (Space Heating) of the National Building Regulations.

NOTE Deleted by amendment No. 1.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies. Information on currently valid national and international standards can be obtained from the South African Bureau of Standards.

SANS 10177-5, *Fire testing of materials, components and elements used in buildings – Part 5: Non-combustibility at 750 °C of building materials*.

SANS 10400-A, *The application of the National Building Regulations – Part A: General principles and requirements*.

SANS 10400-B, *The application of the National Building Regulations – Part B: Structural design*.

3 Definitions

For the purposes of this document, the definitions given in SANS 10400-A (some of which are repeated for convenience) and the following apply.

3.1

chimney

that part of a building which forms part of a flue, but does not include a flue pipe

3.2

deemed-to-satisfy requirement

non-mandatory requirement, the compliance with which ensures compliance with a functional regulation

SANS 10400-V:2018

Edition 3.1

3.3

dwelling house

single dwelling unit and any garage and other domestic outbuildings thereto, situated on its own site

3.4

dwelling unit

unit containing one or more habitable rooms and provided with adequate sanitary and cooking facilities

3.5

flue

passage which conveys the discharge of a heat-generating appliance to the external air

3.6

flue pipe

pipe forming a flue, but does not include a pipe built as a lining into a chimney

3.7

functional regulation

regulation that sets out in qualitative terms what is required of a building or building element or building component in respect of a particular characteristic, without specifying the method of construction, dimensions or materials to be used

3.8

non-combustible

classified as non-combustible when tested in accordance with SANS 10177-5

3.9

suitable

capable of fulfilling or having fulfilled the intended function or fit for its intended purpose **Amdt 1**

4 Requirements

4.1 General

The functional regulation contained in part V of the National Building Regulations (see annex A) shall be deemed to be satisfied where the design and construction of any flue pipe, chimney, hearth or fireplace comply with the requirements of 4.2 to 4.4.

4.2 Flue pipes

4.2.1 No flue pipe shall be designed and installed in such a manner that it will cause a fire hazard to adjacent material.

4.2.2 No flue pipe shall be connected to a shaft or duct which forms part of a ventilation system.

4.2.3 No flue pipe shall be installed in a shaft or duct in which services which might be adversely affected by heat are to be situated.

4.2.4 Flues penetrating thatch roof shall be of non-combustible material equipped with a suitable spark arrestor not less than 750 mm from the exhaust. **Amdt 1**

NOTE The spark arrestor typically comprises a 10 mm×10 mm×1 mm (minimum) section of stainless steel wire mesh, across the full width of the flue and securely built into the flue around the edges, or supported on mild steel dowels. **Amdt 1**

SANS 10400-V:2018

Edition 3.1

4.3 Chimneys

4.3.1 A chimney which is within or is attached to a building shall comply with the following requirements:

- a) It shall be designed and erected from non-combustible materials and in such a manner that it will not cause a fire hazard to adjacent material.
- b) It shall not be installed in a shaft or duct in which services which might be adversely affected by heat are to be situated.
- c) Combustible material, such as a timber floor joist, trimmer or roof truss, shall not be built within 200 mm of the inside of a chimney.

4.3.2 Where in a dwelling house or dwelling unit the walls of a chimney are made of masonry units, such walls shall be of solid masonry, and where such walls are less than 190 mm thick, such chimney shall be lined in accordance with 4.3.4, provided that such walls shall not be reduced to less than 90 mm in thickness.

4.3.3 Notwithstanding the requirements of 4.3.2, the thickness of a chimney wall in a building covered by a combustible roof shall be not less than 190 mm.

4.3.4 Where a chimney is provided with a flue lining, such lining shall be made of material which will withstand any action of the flue gases and will resist, without cracking or softening, the temperatures to which it might be subjected, and it shall extend throughout the full height of such chimney.

4.3.5 Where a chimney has either a laterally unsupported height greater than 4 m or a laterally unsupported height greater than four and a half times its minimum lateral dimension, it shall be designed in accordance with the requirements of SANS 10400-B.

4.3.6 The height of a chimney outlet shall be not less than (see figure 1)

- a) 1 m above the highest point of contact between such chimney and the roof, provided that where a roof has an angle of slope on both sides of a ridge of not less than 10° from the horizontal and the centre line of the flue of the chimney is not more than 600 mm from the ridge, the height of such chimney outlet shall be not less than 600 mm above such ridge,
- b) 1 m above the highest point of a window or roof light capable of being opened or a ventilation inlet situated in a roof or external wall where the horizontal distance from the nearest point of such window, roof light or opening to a vertical line through the centre of such chimney outlet is less than 2,3 m,
- c) 1 m above the eaves level in the case of a chimney which does not pass through the roof of a building but is within 1,5 m of the nearest wall of such building, provided that at a gable end of such building, such chimney shall extend not less than 600 mm above the highest point of such gable end, and
- d) 1 m measured from the top of the stack, closest to the roof covering above the thatch covering of the roof.

Amdt 1

4.4 Hearths and fireplaces

4.4.1 Every fireplace used for the burning of solid fuel shall have a hearth made of non-combustible material of adequate thickness.

SANS 10400-V:2018


Edition 3.1

4.4.2 Such hearth shall extend not less than 500 mm in front of the grate or fire basket and not less than 300 mm beyond each side of such grate or fire basket.


4.4.3 No timber floor joist or trimmer or any other combustible material shall be built into a hearth.




a) Roof pitch less than 10°



b) Roof pitch 10° or more



c) Opening or adjacent structure



d) Thatch roofs

Amdt 1

Figure 1 — Chimney positions

Annex A

Deleted by amendment No. 1.