



A map of a residential area showing several lots. Lot 2234 is highlighted in red. The lots are numbered 2121, 2122, 2095, 2231, 2232, 2233, 2234, 2235, 2236, 2237, and 2238. The streets are labeled MIMOSA STREET and KEURBOOM STREET.

City/Town	Latitude	Zone	Nett Floor Area	Fenestation Area	Glazing %
Jeffreys Bay	34	4	83,67	20,26	24,21

EX.V7	1161,00	1736,00	2,04	642,20	300,00	N	0,34
Summary							
City/Town	Latitude	Zone	Nett Floor Area	Fenestation Area	Glazing %		
Jeffreys Bay	34	4	154,17	38,15	24,75		



Ex.W11	563,00	176,00	0,99	150,00	500,00	E	0,54
Ex.W12	563,00	170,00	0,99	155,00	500,00	S	0,54
Ex.W13	842,00	817,00	0,69	155,00	500,00	SE	0,54

Summary

City/Town	Latitude	Zone	Nett Floor Area	Fenestration Area	Glazing %
Port Elizabeth	33.962	4	91,25	32,81	35,96

TOWN PLANNING INFO.

4	FLOOR INSULATION for under floor heating	The floors are in accordance with the requirements of 5.4 5.4.1. Surface bed (Heated) 5.4.2. Suspended (Exposed) R-value => 1.00	<table border="1"> <tr> <th>Under slab (Heated):</th><th>mm</th><th>W/m.K</th><th>R-Val.</th></tr> <tr> <td>Lambda board</td><td>000</td><td>0.024</td><td>0.00</td></tr> <tr> <td>Total R-value:</td><td>Req. =>1.0</td><td>1.00</td><td>N/A</td></tr> <tr> <th>Suspended Floor (Exposed):</th><th>mm</th><th>W/m.K</th><th>R-Val.</th></tr> <tr> <td>Lambda board</td><td>000</td><td>0.024</td><td>0.00</td></tr> <tr> <td>Total R-value:</td><td>Req. =>1.0</td><td>0.00</td><td>In order</td></tr> </table>	Under slab (Heated):	mm	W/m.K	R-Val.	Lambda board	000	0.024	0.00	Total R-value:	Req. =>1.0	1.00	N/A	Suspended Floor (Exposed):	mm	W/m.K	R-Val.	Lambda board	000	0.024	0.00	Total R-value:	Req. =>1.0	0.00	In order																
Under slab (Heated):	mm	W/m.K	R-Val.																																								
Lambda board	000	0.024	0.00																																								
Total R-value:	Req. =>1.0	1.00	N/A																																								
Suspended Floor (Exposed):	mm	W/m.K	R-Val.																																								
Lambda board	000	0.024	0.00																																								
Total R-value:	Req. =>1.0	0.00	In order																																								
5	EXTERNAL WALLS Surface density > 270kg/m²	The external walls are in accordance with the requirements of 5.5 (Table 6) Zone 4: 50mm Cavity wall: R-value => 0.6	<table border="1"> <tr> <th>External wall:</th><th>mm</th><th>W/m.K</th><th>R-Val.</th></tr> <tr> <td>Outer Air-film (1/20)</td><td>1000</td><td>20</td><td>0.05</td></tr> <tr> <td>15mm plaster</td><td>15</td><td>0.75</td><td>0.02</td></tr> <tr> <td>110mm Brick</td><td>110</td><td>0.82</td><td>0.13</td></tr> <tr> <td>Air-spaces</td><td>1000</td><td>6.8</td><td>0.15</td></tr> <tr> <td>Cavity (Lambda board)</td><td>000</td><td>0.024</td><td>0.00</td></tr> <tr> <td>110mm Brick</td><td>110</td><td>0.82</td><td>0.13</td></tr> <tr> <td>15mm plaster</td><td>15</td><td>0.75</td><td>0.02</td></tr> <tr> <td>Inner Air-Film (1/9.4)</td><td>1000</td><td>9.4</td><td>0.11</td></tr> <tr> <td>Total R-value:</td><td>Req. =>0.60</td><td>0.61</td><td>In order</td></tr> </table>	External wall:	mm	W/m.K	R-Val.	Outer Air-film (1/20)	1000	20	0.05	15mm plaster	15	0.75	0.02	110mm Brick	110	0.82	0.13	Air-spaces	1000	6.8	0.15	Cavity (Lambda board)	000	0.024	0.00	110mm Brick	110	0.82	0.13	15mm plaster	15	0.75	0.02	Inner Air-Film (1/9.4)	1000	9.4	0.11	Total R-value:	Req. =>0.60	0.61	In order
External wall:	mm	W/m.K	R-Val.																																								
Outer Air-film (1/20)	1000	20	0.05																																								
15mm plaster	15	0.75	0.02																																								
110mm Brick	110	0.82	0.13																																								
Air-spaces	1000	6.8	0.15																																								
Cavity (Lambda board)	000	0.024	0.00																																								
110mm Brick	110	0.82	0.13																																								
15mm plaster	15	0.75	0.02																																								
Inner Air-Film (1/9.4)	1000	9.4	0.11																																								
Total R-value:	Req. =>0.60	0.61	In order																																								
6	ROOF & CEILING ASSEMBLY	The roof and ceiling assemblies are in accordance with the requirements of 5.6 Zone: 4 Direction of Flow: UP 22" Metal roof with angled ceiling	<table border="1"> <tr> <th>5" MONO PITCH ROOF</th><th>mm</th><th>W/m.K</th><th>R-Val.</th></tr> <tr> <td>Outer Air-film (1/20)</td><td>n/a</td><td>n/a</td><td>0.05</td></tr> <tr> <td>Metal Roofing sheeling</td><td>0.00</td><td>53.00</td><td>0.00</td></tr> <tr> <td>Air-space & Slatolam</td><td>n/a</td><td>n/a</td><td>0.51</td></tr> <tr> <td>Isover Aerolite insulation</td><td>50.0</td><td>0.044</td><td>1.14</td></tr> <tr> <td>Isover Aerolite insulation</td><td>75.0</td><td>0.04</td><td>1.88</td></tr> <tr> <td>Gypsum Ceiling</td><td>6.40</td><td>0.17</td><td>0.04</td></tr> <tr> <td>Inner Air-Film (1/11.0)</td><td>n/a</td><td>n/a</td><td>0.09</td></tr> <tr> <td>Total R-value:</td><td>Req. =>3.7</td><td>3.71</td><td>In order</td></tr> </table>	5" MONO PITCH ROOF	mm	W/m.K	R-Val.	Outer Air-film (1/20)	n/a	n/a	0.05	Metal Roofing sheeling	0.00	53.00	0.00	Air-space & Slatolam	n/a	n/a	0.51	Isover Aerolite insulation	50.0	0.044	1.14	Isover Aerolite insulation	75.0	0.04	1.88	Gypsum Ceiling	6.40	0.17	0.04	Inner Air-Film (1/11.0)	n/a	n/a	0.09	Total R-value:	Req. =>3.7	3.71	In order				
5" MONO PITCH ROOF	mm	W/m.K	R-Val.																																								
Outer Air-film (1/20)	n/a	n/a	0.05																																								
Metal Roofing sheeling	0.00	53.00	0.00																																								
Air-space & Slatolam	n/a	n/a	0.51																																								
Isover Aerolite insulation	50.0	0.044	1.14																																								
Isover Aerolite insulation	75.0	0.04	1.88																																								
Gypsum Ceiling	6.40	0.17	0.04																																								
Inner Air-Film (1/11.0)	n/a	n/a	0.09																																								
Total R-value:	Req. =>3.7	3.71	In order																																								
7	BUILDING SEALING	The building sealing is in accordance with the requirements of 5.7	A foam or rubber compressible strip or a fibrous seal to restrict air leakage shall be fitted to each edge of an external door and other such opening that serves a habitable room. The maximum air leakage for windows and doors shall comply with the requirements of SANS 613. In order																																								
8	HOT WATER Classification H4 - Dwelling house	The building hot water is in accordance with the requirements of 6.1	NO ADDITIONAL BEDROOMS WERE ADDED.																																								
	PIPE INSULATION (hot water pipe)	Internal pipe diameter ≤ 80mm: Minimum R-value of 1.00	<table border="1"> <tr> <th>Closed cell elastomeric thermal insulation</th><th>mm</th><th>W/m.K</th><th>R-Val.</th></tr> <tr> <td></td><td>38</td><td>0.036</td><td>1.06</td></tr> <tr> <td>Total R-value:</td><td>Req. 1.0</td><td>1.06</td><td>In order</td></tr> </table>	Closed cell elastomeric thermal insulation	mm	W/m.K	R-Val.		38	0.036	1.06	Total R-value:	Req. 1.0	1.06	In order																												
Closed cell elastomeric thermal insulation	mm	W/m.K	R-Val.																																								
	38	0.036	1.06																																								
Total R-value:	Req. 1.0	1.06	In order																																								
9	LIGHTING Classification H4	The building lighting is in accordance with the requirements of 6.2	LED & CFL deemed to comply with Table 12 for H3 & H4 In order																																								

GENERAL NOTES:

[illegible]

DRAWING TITLE:

MUNICIPAL SUBMISSIONS

PROJECT TITLE:

ADDITIONS AND ALTERATIONS ON ERF
2234, JEFFREYS BAY, WAVECREST,
JEFFREYS BAY FOR ~~Explo~~ Tech SA (PTY)
LTD



 CLIENT SIGNATURE

bh **BLACKHOUND**
ARCHITECTURE & RENDERING

dewald@blackhoundenterprises.com
072 799 9597 | 072 418 6867
https://blackhoundenterprises.com
Unit 10, The Network, 19 Cactus Rd
Fairview, Port Elizabeth, 6070

25 Nov 25

PROFESSIONAL SIGNATURE

MUNICIPAL INFORMATION:

AGE OF BUILDING:	28
------------------	----



COPYRIGHT:

This drawing is subject to copyright, and may not be reproduced in whole or part in any matter whatsoever without written permission from Blackboud Architecture & Rendering.

PROJECT NO.:

2023_HouseRossouw

DRAWING NO.:

20251125_HouseRossouw_MS01

DRAWN BY:
DMP

PRINT DATE:

PAGE SIZE:

25 Nov 2025 A1

REVISION NO.:

00

00
SHEET NO. :

SHEET NO.:

001

001

001